Eddie Renfrew

Group Commander

Strathclyde Fire & Rescue



Firefighting in High-Rise Buildings

....a high-rise building is considered to be "one which contains floors at such a height that external rescue and firefighting are not feasible"







Bridgehead

- The nearest available unaffected floor <u>below</u> the fire
- The forward control point
- The floor from which all fire fighting and rescue operations are carried out



The Dalmarnock Fire Tests

The Uncontrolled Fire

High-pressure spray from a hand controlled branch employed for 2 reasons: -

- •Fastest possible cooling of fire gases
- Least possible water damage



Breathing Apparatus Procedure

- BA teams minimum of 2 FF's in each team
- 'Time-in' strictly controlled
- Normal duration 48mins
- Reduced to 20mins hard work / high temp



Other duties: -

- Incident Commander
- Pump operator & 1 FF Hose/hydrant
- 1 FF ground safety
- Operations Commander
- 1 FF BA entry control officer
- 1 FF control of fire lift



The Dalmarnock Fire Tests

The Controlled Fire



Eddie Renfrew

Group Commander

Strathclyde Fire & Rescue

